

# **ORDINANCE NO. 8313**

# AN ORDINANCE GRANTING APPROVAL OF TEXT AMENDMENTS TO TITLE 15, CHAPTER 150 OF THE LOMBARD VILLAGE CODE

(Local Amendments to Chapter 150 of Village Code)

WHEREAS, the Village of Lombard maintains a Building Code which is found in Title 15, Chapter 150 of the Lombard Code of Ordinances; and,

WHEREAS, the Board of Trustees deem it reasonable to periodically review said Building Code and make necessary changes; and,

WHEREAS, a review of the Building Code has been conducted by the Village of Lombard Board of Building Appeals on November 6, 2024; and,

WHEREAS, the Board of Building Appeals has filed its recommendations with the President and Board of Trustees recommending approval of the text amendments described herein; and,

NOW, THEREFORE, BE IT ORDAINED BY THE PRESIDENT AND BOARD OF TRUSTEES OF THE VILLAGE OF LOMBARD, DU PAGE COUNTY, ILLINOIS, as follows:

**SECTION 1:** That Title 15, Chapter 150, Section 150.060 of the Lombard Village Code shall be amended to add text as underscored and delete text that is in strikeout, as set forth within Attachment "A" attached hereto and made a part hereof.

**SECTION 2:** That this ordinance shall be in full force and effect after its passage, approval and publication in pamphlet form as provided by law.

Passed on first reading this 21st day of November 2024.

First reading waived by action of the Board of Trustees this \_\_\_\_\_day of \_\_\_\_\_, 2022.

Passed on second reading this 5th day of December 2024.

Ayes: Trustee LaVaque, Puccio, Dudek, Militello and Bachner

Nays: None

Absent: None

Ordinance No. 8313 Re: Chapter 150 Page 2

Approved by me this 5th day of December 2024.

Keith T. Giagnorio, Village President

ATTEST:

aber Brens Elizabeth Brezinski, Village Clerk

Published by me in pamphlet form this 6th day December 2024.

Jaber Brezinski, Village Clerk

Ordinance No. 8313 Re: Chapter 150 Page 3

a.

30

# **EXHIBIT A TEXT AMENDMENTS TO CHAPER 150 OF VILLAGE CODE**

See attached pages

# ARTICLE VIII. NATIONAL ELECTRICAL CODE - 2017 2023

# § 150.060 Establishment of rules and regulations of electrical installation.

The National Electrical Code (2017 2023 edition), as hereby amended and as modified by this Chapter, shall establish the rules and regulations of electrical installations in the village.

(Ord. No. 7137, 1, passed 10-15-15; Ord. No. 7793, § 1, passed 3-5-20)

## § 150.061 Definition.

For the purpose of this Chapter the following definitions shall apply unless the context clearly indicates or requires a different meaning.

*Communications contractor* is one that installs only Class 2 or Class 3 type wiring as defined in Articles 725.1 and 725.2 of the National Electrical Code (2017-2023 Edition) (NEC), and only that portion of the wiring system between the load side of a Class 2 or Class 3 power source and the connected equipment.

*Electrical contractor* as used in this Chapter means any person, firm or corporation engaged in the business of installing or altering, by contract or otherwise, electrical equipment for the utilization of electricity supplied for light, heat or power or other installations covered in Article 90.2, Scope of the National Electrical Code (2017-2023 Edition); but "electrical contractor" does not include employees of such contractor who perform or supervise such work.

(Ord. 5481, Passed 5/6/04; Ord. 6522, passed 9/16/10; Ord. No. 7137, 1, passed 10-15-15; Ord. No. 7793, § 1, passed 3-5-20)

## § 150.062 Electrical contractors and communications contractor requirements.

It is unlawful for any person, firm or corporation to engage in the business of electrical contractor or communications contractor within the Village, without meeting the provisions as set forth below.

- (A) Registration and Insurance. Any person, firm or corporation desiring to engage in the business of an electrical contractor or communications contractor shall meet the registration and insurance requirements as set forth within Section 150.143.
- (B) Use of permit issued to another. It shall be unlawful for any person to install, alter or repair any electrical wires or apparatus by authority of a permit issued to and for the use of some other person.
- (C) Permit for person not entitled to one. It shall be unlawful for any registered Electrical or Communications Contractor to secure or furnish a permit for the installation, alteration, and repair of electrical wires and apparatus to any person not entitled to such permit under the regulations of this Chapter.
- (D) Revocation of permits. The Community Development Director or his/her designee is authorized to revoke any permit or certificate obtained by fraud, misrepresentation, or in any way contrary to the provisions of the electrical regulations of this Chapter, for installation, alteration, repair and use of any electrical conductors, electrical equipment, signaling & communications conductors and equipment, and fiber optic cables and raceways.

(Ord. 6522, passed 9/16/10; Ord. 6832, passed 5/17/13; Ord. No. 7137, 1, passed 10-15-15; Ord. No. 7890, §§ 1, 3, passed 12-3-20)

#### § 150.063 Permit required.

No person shall install any electrical conduits, electrical wires, electrical equipment, apparatus or communications, data, computer or fiber optics cables, conduits, equipment or apparatus in any building or structure, for which a permit is required, until such permit shall have been secured. In case any work is begun without a permit authorizing said work, the Community Development Director or his/her designee shall have the power to stop said work and order all persons engaged therein to stop and desist until the proper permit is secured.

Underground installations in the parkway area require an additional permit (right-of-way permit) from the Village of Lombard Public Works Department.

(Ord. 6522, passed 9/16/10)

#### § 150.064 Disconnection of electrical services.

- (A) If any person violates the provisions of this Chapter or maintains any electrical wiring or apparatus or communication, data, computer, or fiber optic cable or equipment found to be dangerous to life and property, the Community Development Director or his/her designee is hereby empowered to cut-off or otherwise disconnect current to said electrical wires or apparatus.
- (B) Any person having been stopped from installing electrical work as outlined in § 150.063 shall, when securing the permit to continue, pay double the permit fees as a penalty.

(Ord. 6522, passed 9/16/10; Ord. No. 7137, 1, passed 10-15-15)

## § 150.065 Permit fees.

All fees for inspection shall be in accordance with schedules under § 150.140.

#### § 150.066 Adoption by reference amendments, additions, and deletions.

(A) The National Electrical Code (2017-2023 edition), as amended, is adopted by reference as modified by this Chapter.

In the event any provisions, Articles, wording, and the like, of the National Electrical Code (2017-2023 edition), as amended, are in conflict with any ordinances, amendments, and/or addendums, as recognized and approved by the Electrical Commission of the Village of Lombard and/or as adopted by the Village of Lombard, or in conflict with the state law, the most restrictive provisions, Articles, wording, and the like, shall prevail.

Wiring methods and/or materials listed by the National Electrical Code (<del>2017</del>-<u>2023</u> Edition), but amended, deleted, prohibited or requiring special expressed written permission (SEWP) by this Chapter as noted in subsections (B), (C), (D) below shall be considered to be amended, deleted, prohibited or requiring special expressed written permission (SEWP) where ever and there after mentioned or referenced in the National Electrical Code (<del>2017</del>-<u>2023</u> edition).

(B) The following Articles, or portions thereof, of the National Electric Code (2017-2023 Edition) shall be deleted for the purpose of this Chapter:

(Supp. No. 21, Update 1)

Created: 2024-10-22 16:12:16 [EST]

#### Section 230.41. Ex.(4)

Aluminum wire is not allowed, except AA-8000 series electrical grade aluminum conductors are approved for outside use to feed an electric meter only.

Article 320 Armored Cable: Type AC

Article 322 Flat Cable Assemblies: Type FC

<u>Article 324</u> Flat Conductor Cable: Type FCC

<u>Article 334</u> Nonmetallic Sheathed Cable: Type NM, NMC, & NMS

<u>Article 338</u> Service Entrance Cable: Type SE & USE

<u>Article 362</u> Electrical Nonmetallic Tubing: Type ENT

Article 394 Concealed Knob & Tube

<u>Article 330</u> Metal Clad Cable: Type MC when extended a length of greater twenty (20) feet per circuit.

- (C) Certain constructions recognized by the National Electrical Code (NEC) shall only be permitted with the special expressed written permission (SEWP) of the Building Division of the Community Development Department.
- (D) The following Articles or Sections of the National Electric Code (2017-2023 Edition) are amended as follows:

Section 110.14 Electrical Connections. (Add the following:)

- (A) *Terminals*. The use of stab type screwless pressure terminals of the conductor push-in type is prohibited.
- (B) *Splices.* The use of device terminals for splicing is strictly prohibited.

Section 110.26 Spaces About Electric Equipment. (Add the following:)

(A) Dead Front Assemblies—When in the judgment of the Electrical Inspector or his/her designee, the conditions of the installation or the equipment being installed or modified require additional clearances at front, sides or rear of electrical equipment, such additional clearances shall be provided.

Section 210.12 – Arc-Fault Circuit Interrupter Protection (Add the following:)

Exception No.1 to 210.12(A), (B), (C), (D) and (E): it shall be permitted to omit AFCI protection for the portion of the branch circuit enclosed in rigid metal conduit (RMC), intermediate medal conduit (IMC), electrical metal tubing (EMT) along with metal outlet and junction boxes.

Section 210.19 Conductors—Minimum Ampacity and Size. (Add the following:)

(1) General. All branch circuits shall be wired with copper conductors only.

#### Article 210

III. Required Outlets

#### Section 210.52

(G) (3) Where an installation includes a sump pump or pumps and an ejector pump or pumps, each pump shall be provided an Individual Branch Circuit (dedicated circuit) compliant with Section 210.21(B)(1), (2) and (3). That is, a receptacle with a rating of not less than the branch circuit rating (usually 20 amperes) and compliant with Section 210.8 210.8 (D)#6 and 422.5(A)#6, (GFCI protected) and with Section 406.11 406.12, TR (Tamper Resistant). Where in wet locations Section 406.9(B) WR (Weather Resistant) outlets are required in addition to "In Use" covers.

Exception: A single receptacle (Simplex type and rated for the branch circuit ampacity) installed exclusively for sump pump or pumps and ejector pump or pumps, no GFCI protection is required, amending 210.8. 210.8(D)#6 and 422.5(A)#6.

#### Section 230.1 Scope (Add the following:)

A maximum of one electric service shall be allowed per single family, two family or townhome lot.

Whenever a service is revised or replaced, all current pertinent provisions of this Chapter shall apply.

All service and feeder conductors shall be copper. It is intended that all electrical conductors be copper.

Section 230.43 Wiring Methods for 600 Volts, Nominal, or Less. (Delete the following methods:)

(1) Open Wiring on insulators; (2) TYPE IGS Cable; (5) Electrical metallic tubing; (6) Electrical Nonmetallic Tubing; (7) Service-entrance cables; (13) Type MC cable; (14) Mineral-insulated, metal-sheathed cable; (15) Flexible metal conduit and LFMC, Liquidtight flexible metal conduit; (16) Liquid tight flexible nonmetallic conduit; (17) High density polyethylene conduit (HDPE); (18) Nonmetallic underground conduit with conductors (NUCC); (19) Reinforced thermosetting resin conduit (RTRC); (20) Type TC-ER cable where identified for use as service entrance conductors; (21) Flexible bus system.

Section 230.70 General.

- (A) Location.
  - (1) Readily Accessible Location. (Amend to read as follows:) The service disconnecting means shall be installed at a readily accessible location either outside of a building or structure, or inside nearest the point of entrance of the service conductors, in any case within five (5) feet of conduit and conductor entrance to the building.

Section 230.71 Maximum Number of Disconnects. (Replace NEC text with the following:)

- (A) General. The service disconnecting means for each service permitted by Section 230.2, or for each set of service-entrance conductors permitted by Section 230.40, Exception Nos. 1, 3, 4 or 5, shall consist of one main switch or circuit breaker. There shall be no more than six (6) main disconnects grouped in any one location. For the purpose of this Section, disconnecting means installed as part of listed equipment and used solely for the following shall not be considered a service disconnecting means:
  - (1) -- Power monitoring equipment
  - (2) Surge-protective device(s)
  - (3) Control circuit of the ground-fault protection system
  - (4) Power operable service disconnecting means

<u>Section 250.64</u> Grounding Electrode Conductor Installation. (Delete (A) and (B) and replace with the following:)

- (A) Only Copper grounding and bonding conductors are allowed.
- (B) Securing and Protection from Physical Damage. A grounding electrode conductor or its enclosure shall be securely fastened to the surface on which it is carried. All grounding electrode conductors shall be in an approved raceway. The following raceways shall be approved: rigid metal conduit, intermediate metal conduit, rigid nonmetallic conduit (Schedule 40 and 80) for exterior use; electrical metallic tubing or cable armor for interior use. (C), (D), (E), & (F), (Retain NEC text.)

Article 340 (Add the following:)

UF & BC Cable: Type UF

Approved for use only in exterior underground installations without Special Expressed Written Permission (SEWP); all other uses require SEWP. Article 340 otherwise applies entirely.

Article 348 (Add the following:)

Flexible Metal Conduit: Type FMC

Not approved for use as a general wiring method. Article 348 otherwise applies entirely.

Article 350 (Add the following:)

Liquidtight Flexible Metal Conduit: Type LFMC

Not approved for use as a general wiring method. Article 350 otherwise applies entirely.

Article 352 (Add the following:)

Rigid Nonmetallic conduit: Type RNC

Not approved for use as a general wiring method. Approved for use only in exterior underground installations without Special Expressed Written Permission (SEWP); all other uses require (SEWP). Article 352 otherwise applies entirely.

Article 366 (Add the following:)

Auxiliary gutters: Metal only are allowed. Article 366 otherwise applies entirely.

Section-410.2 Definitions. Section 410.16 Luminaires in clothes closet.

Closet Storage Space: (Add the following:)

In residential occupancies, all clothes closets over six (6) square feet shall have an approved (listed for use) luminaire installed.

Section 545.4 Manufactured Building—Wiring methods.

(Replace (A) and (B) with the following):

Only wiring methods and materials previously approved by this Chapter shall be authorized for use in manufactured buildings, except that those constructions which require Special Expressed Written Permission (SEWP) for use may be considered on a case by case basis.

Section 600.21 Ballasts, Transformers and Electronic Power Supplies.

(A) Accessibility. (Add the following:)

A code approved enclosure designed for that purpose including a self-contained disconnecting means or a disconnecting means installed within (3) three feet and in sight is required.

<sup>(</sup>Supp. No. 21, Update 1)

(Ord. 3267, passed 6/21/90; Ord. 5481, passed 5/6/04; Ord. 6522, passed 9/16/10; Ord. 6832, passed 5/17/13; Ord. No. 7137, 1, passed 10-15-15; Ord. No. 7284, § 1, passed 10-20-16; Ord. No. 7793, § 1, passed 3-5-20; Ord. No. 8118, § 1, passed 1-5-23)